

## OPERATION INSTRUCTIONS

1. When the front cover is closed the System will always start in motion sensor mode. The Green LED will flash. This will flash for a 20-minute period.
  - a. The Green LED will flash for 20 minutes.
  - b. The unit will self-activate every 3 hours.
2. To change to 'PIR Sensor' mode to Constant, press the RED button to the IN-Position.
  - a. The Green LED remain solid.
  - b. The unit will be on continuously 24/7
3. To de-power the system for maintenance unlock from the bottom and drop the front cover down (everything will shut down for user safety).
4. Once the front cover is closed again the system will reset and start in 'Constant ON' mode.

**Slide Switch - Fan speed control can also be changed through the 3 speeds at any point.**

## IDEAL POSITIONING IN VARIOUS LOCATIONS:

Male toilets:

- The unit must be placed just above the urinal
- Not under or near the extraction fan
- Always install not higher than 1.8 meter from floor (6.2 feet from floor).

Female toilets:

- Close to WC

Baby change area:

- Above nappy bin

Disable toilet:

- Above WC

Other area's:

- Near malodours.

Larger area's and odourous area's:

- Install 2 units

**Always install not higher than 1.8 meter from floor (6 feet from floor).**